

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1190059

Product: Sheet-metal switchgear empty enclosure

Type: ESO-II

Rating: IP55, 54; IK 10,08; indoor use
height 1000-2250 mm
width 500-2000 mm
dept 300-1000 mm

Ordering firm: SENCO Příbram spol. s r.o.
Příbram I 292, 261 01 Příbram I, Czech Republic

Manufacturer: SENCO Příbram spol. s r.o.
Příbram I 292, 261 01 Příbram I, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 910038-01/01 of: 24.01.2019

A sample of the product was found to be in conformity with:
ČSN EN 62208 ed. 2:12 cl. 4, 6.2, 6.3, 9.3, 9.4, 9.7, 9.8, 9.11, 9.13, 9.14

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EŽÚ certificate" certification scheme and on the basis of agreement No. 910038 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.01.2022

25.01.2019

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



910038-01