

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFIKÁT

č.: 1170765

Výrobek: Oceloplechová rozváděčová skříň

Typ: RIO-N090/25/60 B2LZS61

Jmenovité hodnoty: 900 x 250 x 600 mm, 31 kg

Objednatel: SENCO Příbram spol. s r.o.
Příbram I 292, 261 01 Příbram I, Česká republika

Výrobce: SENCO Příbram spol. s r.o.
Příbram I 292, 261 01 Příbram I, Česká republika

Obchodní značka:

Výsledky zkoušek jsou uvedeny v protokolu č.: 503008-01/01 ze dne 4.11.2017, 503008-01/06 ze dne 4.10.2017

Vzorek zkoušeného výrobku je ve shodě s požadavky:
ČSN EN 62208 ed. 2:12

Jiné údaje:

Certifikát byl vydán na základě splnění požadavků certifikačního schématu „EZÚ certifikát“ a na základě smlouvy č. 503008 mezi objednavatelem a Elektrotechnickým zkušebním ústavem.

Shoda výrobku s uvedenými normami a předpisy zajišťuje shodu výrobku se základními požadavky nařízení vlády č. 118/2016 Sb. v platném znění a certifikát může být použit jako podklad pro EU Prohlášení o shodě podle zákona č. 90/2016 Sb. o posuzování shody stanovených výrobků při jejich dodávání na trh, v platném znění.

Platnost certifikátu je omezena do: 31.10.2020

20.10.2017

V Praze dne

Mgr. Miroslav Sedláček
Vedoucí certifikačního orgánu

razítko



503008-01

CERTIFICATE OF COMPLIANCE

Certificate Number 20140530-E301939
Report Reference E301939-20140526
Issue Date 2014-MAY-30

Issued to: SENCO PRIBRAM SPOL S R O
PLYNARENKA 292
261 01 PRIBRAM CZECH REPUBLIC

**This is to certify that
representative samples of**

INDUSTRIAL CONTROL PANELS
Industrial Control Panels Enclosures, Sheet Metal Cabinet,
Model RIO-N Series

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

UL 508A, Standard for Industrial Control Panels
UL 50E, Enclosures for Electrical Equipment
CSA C22.2 No. 14-13, Industrial Control Equipment
CAN/CSA-C22.2 No. 94.2-07, Enclosure for Electrical
Equipment, Environmental Considerations

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

